

**Zertifikat** *Certificate*  
mit überwachter Konformität *of surveyed conformity*



Zertifikat Nr. *Certificate No.* Blatt *Page*  
J 50240806 0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum	<i>Date of Issue</i> (day/mo/yr)
	05-JP- 16044232 001	15.11.2012	

Genehmigungsinhaber <i>License Holder</i>	Fertigungsstätte <i>Manufacturing Plant</i>
Yung Li Co., Ltd. Da Pu Industrial Zone Gang Zi Chang Ping Town Dongguan, Guangdong 523571 P.R. China	Yung Li Co., Ltd. Da Pu Industrial Zone Gang Zi Chang Ping Town Dongguan, Guangdong 523571 P.R. China

Prüfzeichen *Test Mark* Geprüft nach *Tested acc. to*  
EN 60309-1:1999+A1:2007 except clause 23  
EN 60309-2:1999+A1:2007 except clause 23



Zertifiziertes Produkt (Geräteidentifikation)  
*Certified Product (Product Identification)*

Lizenzentgelte - Einheit  
*License Fee - Unit*

(Plug for Industrial Purpose)

Type Designation	: 1) YP-316 2) YP-332	8
	3) YP-516 4) YP-532	
Rated Voltage	: 1) AC 200-250V 2) AC 200-250V	
	3) AC 200/346-240/415V	
	4) AC 200/346-240/415V	
Rated Current	: 1) 16A 2) 32A	
	3) 16A 4) 32A	
Position of Earthing Contact	: 6h	
Number of Contact	: 1) 2P+PE 2) 2P+PE	
	3) 3P+N+PE 4) 3P+N+PE	
Kind of Construction	: Standard Sheet 2-II	
Protection Degree	: IP44	

Remark:  
The labelling requirements acc. to EU Directive 2001/95  
have to be observed for distribution within the EEA.  
The installation has to be carried out according to  
installation instruction accompanying the products.



ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.  
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.  
This certificate is based on our Testing and Certification Regulation. The product  
fulfills above mentioned requirements, the production is subject to surveillance.

Zertifizierungsstelle

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg  
Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com  
Fax: +49 221 806-3935 http://www.tuv.com/safety

G. Yin



Certificate No. J 50240806 0001 Our Reference 05-JP-16044232 001 Appendix No. 1

## Constructional Data Form (CDF) for Plug for industrial purpose

Page 1 of 1

License holder:	Yung Li Co., Ltd.
(Full address):	Da Pu Industrial Zone, Gang Zi Chang Ping Town, Dongguan, Guangdong 523571, P.R. China
Factory:	Yung Li Co., Ltd.
(Full address):	Da Pu Industrial Zone, Gang Zi Chang Ping Town, Dongguan, Guangdong 523571, P.R. China

Product	Plug for Industrial Purpose			
Model	YP-316	YP-332	YP-516	YP-532
Rated insulation voltage	250V~	250V~	415V~	415V~
Rated operating voltage	200-250V	200-250V	200/346-240/415V	200/346-240/415V
Rated current	16A	32A	16A	32A
Rated frequency	50/60Hz			
Earthing Facility	With			
Interlock Facility	Without			
IP degree	IP44			
Number of poles	2P + $\perp$	2P + $\perp$	3P + N + $\perp$	3P + N + $\perp$
Series Number	Series I			
Position of earthing contact	6h	6h	6h	6h
Cable connected	H05VV-F 3G2.5mm <sup>2</sup>	H05VV-F 3G4.0mm <sup>2</sup> ; H07RN-F 3G4.0mm <sup>2</sup>	H05VV-F 5G2.5mm <sup>2</sup>	H05VV-F 5G4.0mm <sup>2</sup> ; H07RN-F 5G4.0mm <sup>2</sup>
Method of connecting the cable	Non-rewirable			

Critical component					
Object / part No.	Manufacturer/ trademark	Type / model	Technical data	Standard	Mark(s) of conformity
Enclosure material	Pure Friend Business Enterprise Corp	Flex 600	PVC, V-0, Black	--	UL E174939
	Chia Shin Enterprise Co., Ltd.	CS-9731-WBS	PVC, V-0, Black	--	UL E177713
Pin insert	Dongguan Jin Fuliang Plastic Materials Co., Ltd.	21SPC	PA66, V-2, Red/Blue	--	UL E333203
Fixing cap	Dongguan Jin Fuliang Plastic Materials Co., Ltd.	21SPC	PA66, V-2, Black	--	UL E333203
Pin material	Gem Terminal Ind. Co., Ltd.	C3601	Cu: 59.6%-61.5%	--	Tested with appliance
Cable	Lucky United Electric Wire & Cable Co., Ltd.	H07RN-F	5G4.0mm <sup>2</sup>	DIN VDE 0282-4	VDE 40016757
	Yung-Li Co., Ltd.	H05VV-F	3G2.5mm <sup>2</sup> 3G4.0mm <sup>2</sup>	DIN VDE 0281-5	VDE 40010145

TÜV Rheinland Group

2012.11.05

Jerry Peng

Date

Name



\*Signature